

EU SEER/SCOP Test 欧盟SEER/SCOP测试

Version 1.0

Test Standard 测试标准:	<input checked="" type="checkbox"/> (EU) No 626/2011 <input checked="" type="checkbox"/> (EU) No 206/2012 <input checked="" type="checkbox"/> EN14825 <input checked="" type="checkbox"/> EN 14511 <input checked="" type="checkbox"/> EN12102 <input type="checkbox"/> Other: _____
---------------------	--

GPA requirement: 产品审批要求:	
GPA requirement for rated SEER GPA 的额定制冷季节能效比要求 (%) <div style="border: 1px solid black; display: inline-block; padding: 2px 10px; margin-left: 10px;">>=100%</div>	GPA requirement for rated SCOP GPA 的额定制热季节性能系数要求 (%) <div style="border: 1px solid black; display: inline-block; padding: 2px 10px; margin-left: 10px;">>=100%</div>
GPA requirement for Sound Power GPA 的声功率要求 <div style="border: 1px solid black; display: inline-block; padding: 2px 10px; margin-left: 10px;"><=Rated</div>	
<input checked="" type="checkbox"/> Inverter Single Split type 变频一拖一 分体机 <input type="checkbox"/> On/off Single Split type 定速一拖一 分体机 <input type="checkbox"/> Inverter Multisplit type 变频一拖多 分体机 <input type="checkbox"/> On/off Multisplit type 定速一拖多 分体机	

ERP Hisense Mode: 欧洲海信型号:	ACT52UR4RCC8+AUW52U4RJ8	Manufacturer Model: 工厂型号:	ACT-18UR4RCC8+AUW-18U4RJ8
------------------------------	-------------------------	------------------------------	---------------------------

Test Result:

Function (indicate to which function information applies)	If function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'.
---	--

Cooling		Y				Y			
Heating		Y				Y			
						N			

Item	Symbol	Rated value	Tested Value	Unit	Item	symbol	Rated value	Tested Value	unit
------	--------	-------------	--------------	------	------	--------	-------------	--------------	------

Design load					Seasonal efficiency				
cooling	Pdesignc	5.00	5.010	kW	cooling	SEER	6.70	6.72	—
heating/Average	Pdesignh	4.00	4.000	kW	heating/Average	SCOP(A)	4.40	4.45	—
heating/Warmer	Pdesignh	4.00	4.000	kW	heating/Warmer	SCOP(W)	5.35	5.41	—
heating/Colder	Pdesignh	NA	NA	kW	heating/Colder	SCOP(C)	NA	NA	—

Declared capacity (*) for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj					Declared energy efficiency ratio (*), at indoor temperature 27(19) °C and outdoor temperature Tj				
Tj = 35 °C	Pdc	5.00	5.010	kW	Tj = 35 °C	EERd	3.67	3.71	—
Tj = 30 °C	Pdc	3.70	3.796	kW	Tj = 30 °C	EERd	5.52	5.54	—
Tj = 25 °C	Pdc	2.35	2.415	kW	Tj = 25 °C	EERd	8.20	8.22	—
Tj = 20 °C	Pdc	1.40	1.429	kW	Tj = 20 °C	EERd	10.90	10.93	—

Declared capacity (*) for heating/Average season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Average season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = -7 °C	Pdh	3.52	3.520	kW	Tj = -7 °C	COPd	2.97	2.98	—
Tj = 2 °C	Pdh	2.16	2.210	kW	Tj = 2 °C	COPd	4.37	4.43	—
Tj = 7 °C	Pdh	1.40	1.420	kW	Tj = 7 °C	COPd	5.40	5.52	—
Tj = 12 °C	Pdh	1.30	1.340	kW	Tj = 12 °C	COPd	6.70	6.74	—
Tj = bivalent temperature	Pdh	3.52	3.520	kW	Tj = bivalent temperature	COPd	2.97	2.98	—
Tj = operating limit	Pdh	4.00	4.000	kW	Tj = operating limit	COPd	2.63	2.63	—

Declared capacity (*) for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = 2 °C	Pdh	4.00	4.000	kW	Tj = 2 °C	COPd	3.10	3.15	—
Tj = 7 °C	Pdh	2.56	2.710	kW	Tj = 7 °C	COPd	5.12	5.13	—
Tj = 12 °C	Pdh	1.16	1.230	kW	Tj = 12 °C	COPd	6.08	6.20	—
Tj = bivalent temperature	Pdh	4.00	4.000	kW	Tj = bivalent temperature	COPd	3.10	3.15	—
Tj = operating limit	Pdh	4.00	4.000	kW	Tj = operating limit	COPd	3.10	3.15	—

Declared capacity (*) for heating/Colder season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Colder season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = -7 °C	Pdh	NA	NA	kW	Tj = -7 °C	COPd	NA	NA	—
Tj = 2 °C	Pdh	NA	NA	kW	Tj = 2 °C	COPd	NA	NA	—
Tj = 7 °C	Pdh	NA	NA	kW	Tj = 7 °C	COPd	NA	NA	—
Tj = 12 °C	Pdh	NA	NA	kW	Tj = 12 °C	COPd	NA	NA	—
Tj = bivalent temperature	Pdh	NA	NA	kW	Tj = bivalent temperature	COPd	NA	NA	—
Tj = operating limit	Pdh	NA	NA	kW	Tj = operating limit	COPd	NA	NA	—
Tj = -15 °C	Pdh	NA	NA	kW	Tj = -15 °C	COPd	NA	NA	—

Bivalent temperature					Operating limit temperature				
heating/Average	Tbiv	-7	NA	°C	heating/Average	Tol	-10	NA	°C
heating/Warmer	Tbiv	2	NA	°C	heating/Warmer	Tol	2	NA	°C

heating/Colder	T _{biv}	NA	NA	°C	heating/Colder	T _{ol}	NA	NA	°C
Power consumption of cycling					Efficiency of cycling				
cooling	P _{cycc}	NA	NA	kW	cooling	EER _{cycc}	NA	NA	—
heating	P _{cyh}	NA	NA	kW	heating	COP _{cyh}	NA	NA	—
Degradation co-efficient cooling (**)	C _{dc}	0.25	NA	—	Degradation co-efficient heating (**)	C _{dh}	0.25	NA	—
Electric power input in power modes other than 'active mode'					Seasonal electricity consumption				
off mode	P _{OFF}	0.008	0.008	kW	cooling	Q _{CE}	261	260	kWh/a
standby mode	P _{SB}	0.008	0.008	kW	heating/Average	Q _{HE}	1273	1258	kWh/a
thermostat-off mode	P _{TO}	0.001	0.001	kW	heating/Warmer	Q _{HE}	1047	1035	kWh/a
crankcase heater mode	P _{CK}	0.000	0.000	kW	heating/Colder	Q _{HE}	NA	NA	kWh/a
Capacity control (indicate one of three options)					Other items				
fixed	N				Sound power level (indoor)	LWA	57	56.3	dB(A)
					Sound power level (outdoor)	LWA	64	63.4	dB(A)
staged	N				Global warming potential	GWP	675	0.81	kgCO ₂ eq.
variable	Y				Rated air flow (indoor/outdoor)	—	—	—	m ³ /h
TEST CONCLUSION: 测试结论									
Are the SEER and SCOP TEST results Compliant or Non-Compliant? SEER/SCOP测试是否符合要求?							Compliant		

徐金宇



Tested by (name + signature)

测试员 (姓名, 签名)

Approved by (name + signature)

批准人 (姓名, 签名)