

EU SEER/SCOP Test 欧盟SEER/SCOP测试

Version 1.0

Test Standard 测试标准: <input checked="" type="checkbox"/> (EU) No 626/2011 <input checked="" type="checkbox"/> (EU) No 206/2012 <input checked="" type="checkbox"/> EN14825 <input checked="" type="checkbox"/> EN 14511 <input checked="" type="checkbox"/> ENV 12102 <input type="checkbox"/> Other _____											
GPA requirement: 产品审批要求:											
GPA requirement for rated SEER GPA 的额定制冷季节能效比要求 (%)		>=100%		GPA requirement for rated SCOP GPA 的额定制热季节性能系数要求 (%)		>=100%		GPA requirement for Sound Power GPA 的声功率要求		<=Rated	
<input checked="" type="checkbox"/> Inverter Single Split type 变频一拖一 分体机 <input type="checkbox"/> On/off Single Split type 定速一拖一 分体机 <input type="checkbox"/> Inverter Multisplit type 变频一拖多 分体机 <input type="checkbox"/> On/off Multisplit type 定速一拖多 分体机											
ERP Hisense Mode: 欧洲海信型号:		ADT52UX4RCL8+AUW52U4RJ8			Manufacturer Model: 工厂型号:			ADT-18UX4RCL8+AUW-18U4RJ8			
Test Result:											
Function (indicate to which function information applies)					If function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'.						
Cooling	Y				Average (mandatory)	Y					
Heating	Y				Warmer (if designated)	Y					
					Colder (if designated)	N					
Item	Symbol	Rated value	Tested Value	Unit	Item	symbol	Rated value	Tested Value	unit		
Design load					Seasonal efficiency						
cooling	Pdesignc	5.00	5.080	kW	cooling	SEER	7.00	7.02	—		
heating/Average	Pdesignh	4.00	4.000	kW	heating/Average	SCOP(A)	4.60	4.64	—		
heating/Warmer	Pdesignh	4.00	4.000	kW	heating/Warmer	SCOP(W)	5.35	5.39	—		
heating/Colder	Pdesignh	NA	NA	kW	heating/Colder	SCOP(C)	NA	NA	—		
Declared capacity (*) for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj					Declared energy efficiency ratio (*), at indoor temperature 27(19) °C and outdoor temperature Tj						
Tj = 35 °C	Pdc	5.00	5.080	kW	Tj = 35 °C	EERd	3.90	3.92	—		
Tj = 30 °C	Pdc	3.70	3.810	kW	Tj = 30 °C	EERd	5.60	5.62	—		
Tj = 25 °C	Pdc	2.35	2.460	kW	Tj = 25 °C	EERd	8.48	8.51	—		
Tj = 20 °C	Pdc	1.30	1.340	kW	Tj = 20 °C	EERd	11.50	11.54	—		
Declared capacity (*) for heating/Average season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Average season, at indoor temperature 20 °C and outdoor temperature Tj						
Tj = -7 °C	Pdh	3.52	3.520	kW	Tj = -7 °C	COPd	2.85	2.91	—		
Tj = 2 °C	Pdh	2.16	2.210	kW	Tj = 2 °C	COPd	4.65	4.68	—		
Tj = 7 °C	Pdh	1.40	1.420	kW	Tj = 7 °C	COPd	5.80	5.82	—		
Tj = 12 °C	Pdh	1.30	1.330	kW	Tj = 12 °C	COPd	7.10	7.16	—		
Tj = bivalent temperature	Pdh	3.52	3.520	kW	Tj = bivalent temperature	COPd	2.85	2.91	—		
Tj = operating limit	Pdh	4.00	4.000	kW	Tj = operating limit	COPd	2.70	2.79	—		
Declared capacity (*) for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj						
Tj = 2 °C	Pdh	4.00	4.000	kW	Tj = 2 °C	COPd	3.10	3.15	—		
Tj = 7 °C	Pdh	2.56	2.650	kW	Tj = 7 °C	COPd	4.85	4.88	—		
Tj = 12 °C	Pdh	1.16	1.230	kW	Tj = 12 °C	COPd	6.40	6.43	—		
Tj = bivalent temperature	Pdh	4.00	4.000	kW	Tj = bivalent temperature	COPd	3.10	3.15	—		
Tj = operating limit	Pdh	4.00	4.000	kW	Tj = operating limit	COPd	3.10	3.15	—		
Declared capacity (*) for heating/Colder season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Colder season, at indoor temperature 20 °C and outdoor temperature Tj						
Tj = -7 °C	Pdh	NA	NA	kW	Tj = -7 °C	COPd	NA	NA	—		
Tj = 2 °C	Pdh	NA	NA	kW	Tj = 2 °C	COPd	NA	NA	—		
Tj = 7 °C	Pdh	NA	NA	kW	Tj = 7 °C	COPd	NA	NA	—		
Tj = 12 °C	Pdh	NA	NA	kW	Tj = 12 °C	COPd	NA	NA	—		
Tj = bivalent temperature	Pdh	NA	NA	kW	Tj = bivalent temperature	COPd	NA	NA	—		
Tj = operating limit	Pdh	NA	NA	kW	Tj = operating limit	COPd	NA	NA	—		
Tj = -15 °C	Pdh	NA	NA	kW	Tj = -15 °C	COPd	NA	NA	—		
Bivalent temperature					Operating limit temperature						
heating/Average	Tbiv	-7	NA	°C	heating/Average	Tol	-10	NA	°C		
heating/Warmer	Tbiv	2	NA	°C	heating/Warmer	Tol	2	NA	°C		

heating/Colder	Tbiv	NA	NA	°C	heating/Colder	Tol	NA	NA	°C
Power consumption of cycling					Efficiency of cycling				
cooling	Pcycc	NA	NA	kW	cooling	EERcyc	NA	NA	—
heating	Pcych	NA	NA	kW	heating	COPcyc	NA	NA	—
Degradation co-efficient cooling (**)	Cdc	0.25	NA	—	Degradation co-efficient heating (**)	Cdh	0.25	NA	—
Electric power input in power modes other than 'active mode'					Seasonal electricity consumption				
off mode	P _{OFF}	0.007	0.007	kW	cooling	Q _{CE}	250	249	kWh/a
standby mode	P _{SB}	0.007	0.007	kW	heating/Average	Q _{HE}	1217	1207	kWh/a
thermostat-off mode	P _{TO}	0.001	0.001	kW	heating/Warmer	Q _{HE}	1047	1040	kWh/a
crankcase heater mode	P _{CK}	0.000	0.000	kW	heating/Colder	Q _{HE}	NA	NA	kWh/a
Capacity control (indicate one of three options)					Other items				
fixed	N				Sound power level (indoor)	LWA	57	56.4	dB(A)
					Sound power level (outdoor)	LWA	64	63.4	dB(A)
staged	N				Global warming potential	GWP	675	0.81	kgCO ₂ eq.
variable	Y				Rated air flow (indoor/outdoor)	—	—	—	m ³ /h

TEST CONCLUSION: 测试结论

Are the SEER and SCOP TEST results Compliant or Non-Compliant? SEER/SCOP测试是否符合要求?

Compliant

Tested by (name + signature)

测试员 (姓名, 签名)

Approved by (name + signature)

批准人 (姓名, 签名)