

EU SEER/SCOP Test 欧盟SEER/SCOP测试

Version 1.0

Test Standard 测试标准:	<input checked="" type="checkbox"/> (EU) No 626/2011	<input checked="" type="checkbox"/> (EU) No 206/2012	<input checked="" type="checkbox"/> EN14825	<input checked="" type="checkbox"/> EN 14511	<input checked="" type="checkbox"/> ENV 12102	<input type="checkbox"/> Other _____
---------------------	--	--	---	--	---	--------------------------------------

GPA requirement: 产品审批要求:	
GPA requirement for rated SEER GPA 的额定制冷季节能效比要求 (%)	>=100%
GPA requirement for rated SCOP GPA 的额定制热季节性能系数要求 (%)	>=100%
GPA requirement for Sound Power GPA 的声功率要求	<=Rated
<input checked="" type="checkbox"/> Inverter Single Split type 变频一拖一 分体机 <input type="checkbox"/> On/off Single Split type 定速一拖一 分体机 <input type="checkbox"/> Inverter Multisplit type 变频一拖多 分体机 <input type="checkbox"/> On/off Multisplit type 定速一拖多 分体机	

ERP Hisense Mode: 欧洲海信型号:	AUC105UR4RKC8 & AUW105U4RW8	Manufacturer Model: 工厂型号:	AUC-36UR4RKC8 & AUW-36U4RW8
------------------------------	-----------------------------	------------------------------	-----------------------------

Test Result:

Function (indicate to which function information applies)	If function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'.
---	--

Cooling	Y	Average (mandatory)	Y
Heating	Y	Warmer (if designated)	Y
		Colder (if designated)	N

Item	Symbol	Rated value	Tested Value	Unit	Item	symbol	Rated value	Tested Value	unit
------	--------	-------------	--------------	------	------	--------	-------------	--------------	------

Design load					Seasonal efficiency				
cooling	Pdesignc	10.00	10.000	kW	cooling	SEER	7.50	7.52	—
heating/Average	Pdesignh	8.00	8.000	kW	heating/Average	SCOP(A)	4.60	4.62	—
heating/Warmer	Pdesignh	8.00	8.000	kW	heating/Warmer	SCOP(W)	5.40	5.41	—
heating/Colder	Pdesignh	NA	NA	kW	heating/Colder	SCOP(C)	NA	NA	—

Declared capacity (*) for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj					Declared energy efficiency ratio (*), at indoor temperature 27(19) °C and outdoor temperature Tj				
Tj = 35 °C	Pdc	10.00	10.020	kW	Tj = 35 °C	EERd	3.85	3.86	—
Tj = 30 °C	Pdc	7.40	7.410	kW	Tj = 30 °C	EERd	5.80	5.81	—
Tj = 25 °C	Pdc	4.70	4.730	kW	Tj = 25 °C	EERd	8.25	8.27	—
Tj = 20 °C	Pdc	2.30	2.310	kW	Tj = 20 °C	EERd	14.20	14.25	—

Declared capacity (*) for heating/Average season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Average season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = -7 °C	Pdh	7.04	7.050	kW	Tj = -7 °C	COPd	3.00	3.02	—
Tj = 2 °C	Pdh	4.32	4.340	kW	Tj = 2 °C	COPd	4.62	4.64	—
Tj = 7 °C	Pdh	2.80	2.820	kW	Tj = 7 °C	COPd	5.80	5.81	—
Tj = 12 °C	Pdh	2.00	2.010	kW	Tj = 12 °C	COPd	6.45	6.48	—
Tj = bivalent temperature	Pdh	7.04	7.050	kW	Tj = bivalent temperature	COPd	3.00	3.02	—
Tj = operating limit	Pdh	7.60	7.640	kW	Tj = operating limit	COPd	2.50	2.52	—

Declared capacity (*) for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = 2 °C	Pdh	8.00	8.050	kW	Tj = 2 °C	COPd	2.80	2.81	—
Tj = 7 °C	Pdh	5.12	5.130	kW	Tj = 7 °C	COPd	4.70	4.71	—
Tj = 12 °C	Pdh	2.50	2.510	kW	Tj = 12 °C	COPd	6.80	6.81	—
Tj = bivalent temperature	Pdh	8.00	8.050	kW	Tj = bivalent temperature	COPd	2.80	2.81	—
Tj = operating limit	Pdh	8.00	8.050	kW	Tj = operating limit	COPd	2.80	2.81	—

Declared capacity (*) for heating/Colder season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Colder season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = -7 °C	Pdh	NA	NA	kW	Tj = -7 °C	COPd	NA	NA	—
Tj = 2 °C	Pdh	NA	NA	kW	Tj = 2 °C	COPd	NA	NA	—
Tj = 7 °C	Pdh	NA	NA	kW	Tj = 7 °C	COPd	NA	NA	—
Tj = 12 °C	Pdh	NA	NA	kW	Tj = 12 °C	COPd	NA	NA	—
Tj = bivalent temperature	Pdh	NA	NA	kW	Tj = bivalent temperature	COPd	NA	NA	—
Tj = operating limit	Pdh	NA	NA	kW	Tj = operating limit	COPd	NA	NA	—
Tj = -15 °C	Pdh	NA	NA	kW	Tj = -15 °C	COPd	NA	NA	—

Bivalent temperature					Operating limit temperature				
heating/Average	Tbiv	-7	NA	°C	heating/Average	Tol	-10	NA	°C
heating/Warmer	Tbiv	2	NA	°C	heating/Warmer	Tol	2	NA	°C

heating/Colder	T _{biv}	NA	NA	°C	heating/Colder	T _{ol}	NA	NA	°C
Power consumption of cycling					Efficiency of cycling				
cooling	P _{cycc}	NA	NA	kW	cooling	EER _{cycc}	NA	NA	—
heating	P _{cyh}	NA	NA	kW	heating	COP _{cyh}	NA	NA	—
Degradation co-efficient cooling (**)	C _{dc}	0.25	NA	—	Degradation co-efficient heating (**)	C _{dh}	0.25	NA	—
Electric power input in power modes other than 'active mode'					Seasonal electricity consumption				
off mode	P _{OFF}	0.009	0.009	kW	cooling	Q _{CE}	467	465	kWh/a
standby mode	P _{SB}	0.009	0.009	kW	heating/Average	Q _{HE}	2435	2427	kWh/a
thermostat-off mode	P _{TO}	0.001	0.001	kW	heating/Warmer	Q _{HE}	2074	2071	kWh/a
crankcase heater mode	P _{CK}	0.000	0.000	kW	heating/Colder	Q _{HE}	NA	NA	kWh/a
Capacity control (indicate one of three options)					Other items				
fixed	N				Sound power level (indoor)	LWA	62	61.5	dB(A)
					Sound power level (outdoor)	LWA	69	67.9	dB(A)
staged	N				Global warming potential	GWP	675	0.709	kgCO ₂ eq.
variable	Y				Rated air flow (indoor/outdoor)	—	—	—	m ³ /h
TEST CONCLUSION: 测试结论 Are the SEER and SCOP TEST results Compliant or Non-Compliant? SEER/SCOP测试是否符合要求? Compliant									

徐金宇



Tested by (name + signature)

Approved by (name + signature)

测试员 (姓名, 签名)

批准人 (姓名, 签名)