

EU SEER/SCOP Test 欧盟SEER/SCOP测试

Version 1.0

Test Standard 测试标准: (EU) No 626/2011 (EU) No 206/2012 EN14825 EN 14511 ENV 12102 Other _____

GPA requirement: 产品审批要求:

GPA requirement for rated SEER GPA 的额定制冷季节能效比要求 (%)	>=100%
GPA requirement for rated SCOP GPA 的额定制热季节性系数要求 (%)	>=100%
GPA requirement for Sound Power GPA 的声功率要求	<=Rated

Inverter Single Split type 变频一拖一 分体机
 On/off Single Split type 定速一拖一 分体机
 Inverter Multisplit type 变频一拖多 分体机
 On/off Multisplit type 定速一拖多 分体机

ERP Hisense Mode: 欧洲海信型号:	AUD200UX4RPH8+AUW200U6RZ8	Manufacturer Model: 工厂型号:	AUD-75UX4RPH8+AUW-75U6RZ8
------------------------------	---------------------------	------------------------------	---------------------------

Test Result:

Function (indicate to which function information applies)	If function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'.
---	--

Cooling	Y				Average (mandatory)	Y
Heating	Y				Warmer (if designated)	Y
					Colder (if designated)	N

Item	Symbol	Rated value	Tested Value	Unit	Item	symbol	Rated value	Tested Value	unit
------	--------	-------------	--------------	------	------	--------	-------------	--------------	------

Design load					Seasonal efficiency				
cooling	Pdesignc	19.00	19.030	kW	cooling	SEER	6.00	6.07	—
heating/Average	Pdesignh	17.00	17.000	kW	heating/Average	SCOP(A)	3.90	3.95	—
heating/Warmer	Pdesignh	17.00	17.000	kW	heating/Warmer	SCOP(W)	4.90	4.94	—
heating/Colder	Pdesignh	NA	NA	kW	heating/Colder	SCOP(C)	NA	NA	—

Declared capacity (*) for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj					Declared energy efficiency ratio (*), at indoor temperature 27(19) °C and outdoor temperature Tj				
Tj = 35 °C	Pdc	19.00	19.030	kW	Tj = 35 °C	EERd	3.00	3.03	—
Tj = 30 °C	Pdc	14.06	14.110	kW	Tj = 30 °C	EERd	4.16	4.20	—
Tj = 25 °C	Pdc	8.93	8.950	kW	Tj = 25 °C	EERd	7.00	7.13	—
Tj = 20 °C	Pdc	6.00	6.010	kW	Tj = 20 °C	EERd	11.10	11.15	—

Declared capacity (*) for heating/Average season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Average season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = -7 °C	Pdh	14.96	14.990	kW	Tj = -7 °C	COPd	2.85	2.89	—
Tj = 2 °C	Pdh	9.18	9.200	kW	Tj = 2 °C	COPd	3.64	3.68	—
Tj = 7 °C	Pdh	5.95	5.960	kW	Tj = 7 °C	COPd	5.10	5.17	—
Tj = 12 °C	Pdh	6.30	6.310	kW	Tj = 12 °C	COPd	6.10	6.16	—
Tj = bivalent temperature	Pdh	14.96	14.990	kW	Tj = bivalent temperature	COPd	2.85	2.89	—
Tj = operating limit	Pdh	17.00	17.000	kW	Tj = operating limit	COPd	2.55	2.59	—

Declared capacity (*) for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = 2 °C	Pdh	17.00	17.000	kW	Tj = 2 °C	COPd	2.93	3.02	—
Tj = 7 °C	Pdh	10.88	10.930	kW	Tj = 7 °C	COPd	4.20	4.23	—
Tj = 12 °C	Pdh	4.93	4.950	kW	Tj = 12 °C	COPd	6.10	6.12	—
Tj = bivalent temperature	Pdh	17.00	17.000	kW	Tj = bivalent temperature	COPd	2.93	3.02	—
Tj = operating limit	Pdh	17.00	17.000	kW	Tj = operating limit	COPd	2.93	3.02	—

Declared capacity (*) for heating/Colder season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Colder season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = -7 °C	Pdh	NA	NA	kW	Tj = -7 °C	COPd	NA	NA	—
Tj = 2 °C	Pdh	NA	NA	kW	Tj = 2 °C	COPd	NA	NA	—
Tj = 7 °C	Pdh	NA	NA	kW	Tj = 7 °C	COPd	NA	NA	—
Tj = 12 °C	Pdh	NA	NA	kW	Tj = 12 °C	COPd	NA	NA	—
Tj = bivalent temperature	Pdh	NA	NA	kW	Tj = bivalent temperature	COPd	NA	NA	—
Tj = operating limit	Pdh	NA	NA	kW	Tj = operating limit	COPd	NA	NA	—
Tj = -15 °C	Pdh	NA	NA	kW	Tj = -15 °C	COPd	NA	NA	—

Bivalent temperature					Operating limit temperature				
heating/Average	Tbiv	-7	NA	°C	heating/Average	Tol	-10	NA	°C
heating/Warmer	Tbiv	2	NA	°C	heating/Warmer	Tol	2	NA	°C

heating/Colder	Tbiv	NA	NA	°C	heating/Colder	Tol	NA	NA	°C
Power consumption of cycling					Efficiency of cycling				
cooling	P _{cyc}	NA	NA	kW	cooling	EER _{cyc}	NA	NA	—
heating	P _{ych}	NA	NA	kW	heating	COP _{cyc}	NA	NA	—
Degradation co-efficient cooling (**)	Cdc	0.25	NA	—	Degradation co-efficient heating (**)	Cdh	0.25	NA	—
Electric power input in power modes other than 'active mode'					Seasonal electricity consumption				
off mode	P _{OFF}	0.011	0.011	kW	cooling	Q _{CE}	1282	1268	kWh/a
standby mode	P _{SB}	0.011	0.011	kW	heating/Average	Q _{HE}	6103	6026	kWh/a
thermostat-off mode	P _{TO}	0.002	0.002	kW	heating/Warmer	Q _{HE}	4857	4819	kWh/a
crankcase heater mode	P _{CK}	0.000	0.000	kW	heating/Colder	Q _{HE}	NA	NA	kWh/a
Capacity control (indicate one of three options)					Other items				
fixed	N				Sound power level (indoor)	LWA	81	80.7	dB(A)
					Sound power level (outdoor)	LWA	76	75.5	dB(A)
staged	N				Global warming potential	GWP	675	3.105	kgCO ₂ eq.
variable	Y				Rated air flow (indoor/outdoor)	—	—	—	m ³ /h
TEST CONCLUSION: 测试结论									
Are the SEER and SCOP TEST results Compliant or Non-Compliant? SEER/SCOP测试是否符合要求?							Compliant		

徐金宇



Tested by (name + signature)

测试员 (姓名, 签名)

Approved by (name + signature)

批准人 (姓名, 签名)