

EU SEER/SCOP Test 欧盟SEER/SCOP测试

Version 1.0

Test Standard 测试标准:	<input checked="" type="checkbox"/> (EU) No 626/2011 <input checked="" type="checkbox"/> (EU) No 206/2012 <input checked="" type="checkbox"/> EN14825 <input checked="" type="checkbox"/> EN 14511 <input checked="" type="checkbox"/> EN12102 <input type="checkbox"/> Other: _____
---------------------	--

GPA requirement: 产品审批要求:	
GPA requirement for rated SEER GPA 的额定制冷季节能效比要求 (%) <div style="border: 1px solid black; padding: 2px; display: inline-block; margin-left: 10px;">>=100%</div>	GPA requirement for rated SCOP GPA 的额定制热季节性能系数要求 (%) <div style="border: 1px solid black; padding: 2px; display: inline-block; margin-left: 10px;">>=100%</div>
GPA requirement for Sound Power GPA 的声功率要求 <div style="border: 1px solid black; padding: 2px; display: inline-block; margin-left: 10px;"><=Rated</div>	
<input checked="" type="checkbox"/> Inverter Single Split type 变频一拖一 分体机 <input type="checkbox"/> On/off Single Split type 定速一拖一 分体机 <input type="checkbox"/> Inverter Multisplit type 变频一拖多 分体机 <input type="checkbox"/> On/off Multisplit type 定速一拖多 分体机	

ERP Hisense Mode: 欧洲海信型号:	ACT52UR4RJC8+AUW52U4RJ8	Manufacturer Model: 工厂型号:	AUC-18UR4RJC8+AUW-18U4RJ8
------------------------------	-------------------------	------------------------------	---------------------------

Test Result:

Function (indicate to which function information applies)	If function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'.
---	--

Cooling		Y				Y			
Heating		Y				Y			
						N			

Item	Symbol	Rated value	Tested Value	Unit	Item	symbol	Rated value	Tested Value	unit
------	--------	-------------	--------------	------	------	--------	-------------	--------------	------

Design load					Seasonal efficiency				
cooling	Pdesignc	5.00	5.026	kW	cooling	SEER	7.20	7.21	—
heating/Average	Pdesignh	4.00	4.000	kW	heating/Average	SCOP(A)	4.60	4.68	—
heating/Warmer	Pdesignh	4.00	4.000	kW	heating/Warmer	SCOP(W)	5.35	5.40	—
heating/Colder	Pdesignh	NA	NA	kW	heating/Colder	SCOP(C)	NA	NA	—

Declared capacity (*) for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj					Declared energy efficiency ratio (*), at indoor temperature 27(19) °C and outdoor temperature Tj				
Tj = 35 °C	Pdc	5.00	5.026	kW	Tj = 35 °C	EERd	4.00	4.06	—
Tj = 30 °C	Pdc	3.70	3.768	kW	Tj = 30 °C	EERd	5.85	5.86	—
Tj = 25 °C	Pdc	2.35	2.398	kW	Tj = 25 °C	EERd	9.23	9.23	—
Tj = 20 °C	Pdc	1.20	1.250	kW	Tj = 20 °C	EERd	10.80	10.83	—

Declared capacity (*) for heating/Average season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Average season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = -7 °C	Pdh	3.52	3.650	kW	Tj = -7 °C	COPd	3.00	3.05	—
Tj = 2 °C	Pdh	2.16	2.260	kW	Tj = 2 °C	COPd	4.47	4.55	—
Tj = 7 °C	Pdh	1.40	1.450	kW	Tj = 7 °C	COPd	6.00	6.12	—
Tj = 12 °C	Pdh	1.20	1.350	kW	Tj = 12 °C	COPd	7.40	7.48	—
Tj = bivalent temperature	Pdh	3.52	3.650	kW	Tj = bivalent temperature	COPd	3.00	3.05	—
Tj = operating limit	Pdh	4.00	4.000	kW	Tj = operating limit	COPd	2.55	2.68	—

Declared capacity (*) for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = 2 °C	Pdh	4.00	4.000	kW	Tj = 2 °C	COPd	3.10	3.22	—
Tj = 7 °C	Pdh	2.56	2.650	kW	Tj = 7 °C	COPd	4.90	4.95	—
Tj = 12 °C	Pdh	1.16	1.200	kW	Tj = 12 °C	COPd	6.33	6.37	—
Tj = bivalent temperature	Pdh	4.00	4.000	kW	Tj = bivalent temperature	COPd	3.10	3.22	—
Tj = operating limit	Pdh	4.00	4.000	kW	Tj = operating limit	COPd	3.10	3.22	—

Declared capacity (*) for heating/Colder season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Colder season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = -7 °C	Pdh	NA	NA	kW	Tj = -7 °C	COPd	NA	NA	—
Tj = 2 °C	Pdh	NA	NA	kW	Tj = 2 °C	COPd	NA	NA	—
Tj = 7 °C	Pdh	NA	NA	kW	Tj = 7 °C	COPd	NA	NA	—
Tj = 12 °C	Pdh	NA	NA	kW	Tj = 12 °C	COPd	NA	NA	—
Tj = bivalent temperature	Pdh	NA	NA	kW	Tj = bivalent temperature	COPd	NA	NA	—
Tj = operating limit	Pdh	NA	NA	kW	Tj = operating limit	COPd	NA	NA	—
Tj = -15 °C	Pdh	NA	NA	kW	Tj = -15 °C	COPd	NA	NA	—

Bivalent temperature					Operating limit temperature				
heating/Average	Tbiv	-7	NA	°C	heating/Average	Tol	-10	NA	°C
heating/Warmer	Tbiv	2	NA	°C	heating/Warmer	Tol	2	NA	°C

heating/Colder	Tbiv	NA	NA	°C	heating/Colder	Tol	NA	NA	°C
Power consumption of cycling					Efficiency of cycling				
cooling	Pcyc	NA	NA	kW	cooling	EERcyc	NA	NA	—
heating	Pych	NA	NA	kW	heating	COPcyc	NA	NA	—
Degradation co-efficient cooling (**)	Cdc	0.25	NA	—	Degradation co-efficient heating (**)	Cdh	0.25	NA	—
Electric power input in power modes other than 'active mode'					Seasonal electricity consumption				
off mode	P _{OFF}	0.008	0.008	kW	cooling	Q _{CE}	243	242	kWh/a
standby mode	P _{SB}	0.008	0.008	kW	heating/Average	Q _{HE}	1217	1198	kWh/a
thermostat-off mode	P _{TO}	0.001	0.001	kW	heating/Warmer	Q _{HE}	1047	1036	kWh/a
crankcase heater mode	P _{CK}	0.000	0.000	kW	heating/Colder	Q _{HE}	NA	NA	kWh/a
Capacity control (indicate one of three options)					Other items				
fixed	N				Sound power level (indoor)	LWA	52	51.5	dB(A)
					Sound power level (outdoor)	LWA	64	63.3	dB(A)
staged	N				Global warming potential	GWP	675	0.81	kgCO ₂ eq.
variable	Y				Rated air flow (indoor/outdoor)	—	—	—	m ³ /h
TEST CONCLUSION: 测试结论									
Are the SEER and SCOP TEST results Compliant or Non-Compliant? SEER/SCOP测试是否符合要求?							Compliant		

徐金宇



Tested by (name + signature)

测试员 (姓名, 签名)

Approved by (name + signature)

批准人 (姓名, 签名)