

EU SEER/SCOP Test 欧盟SEER/SCOP测试

Version 1.0

Test Standard 测试标准: (EU) No 626/2011 (EU) No 206/2012 EN14825 EN 14511 ENV 12102 Other _____

GPA requirement: 产品审批要求:

GPA requirement for rated SEER
GPA 的额定制冷季节能效比要求 (%) ≥100%

GPA requirement for rated SCOP
GPA 的额定制热季节性能系数要求 (%) ≥100%

GPA requirement for Sound Power
GPA 的声功率要求 ≤Rated

Inverter Single Split type 变频一拖一 分体机 On/off Single Split type 定速一拖一 分体机 Inverter Multisplit type 变频一拖多 分体机 On/off Multisplit type 定速一拖多 分体机

ERP Hisense Mode: 欧洲海信型号: AUC105UR4RKC8+AUW105U6RN8 Manufacturer Model: 工厂型号: AUC-36UR4RKC8+AUW-36U6RN8

Test Result:

Function (indicate to which function information applies) If function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'.

Cooling	Y	Average (mandatory)	Y
Heating	Y	Warmer (if designated)	Y
		Colder (if designated)	N

Item	Symbol	Rated value	Tested Value	Unit	Item	symbol	Rated value	Tested Value	unit
------	--------	-------------	--------------	------	------	--------	-------------	--------------	------

Design load					Seasonal efficiency				
cooling	Pdesignc	10.00	10.030	kW	cooling	SEER	7.00	7.04	—
heating/Average	Pdesignh	8.00	8.020	kW	heating/Average	SCOP(A)	4.40	4.45	—
heating/Warmer	Pdesignh	8.00	8.020	kW	heating/Warmer	SCOP(W)	5.35	5.40	—
heating/Colder	Pdesignh	NA	NA	kW	heating/Colder	SCOP(C)	NA	NA	—

Declared capacity (*) for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj					Declared energy efficiency ratio (*), at indoor temperature 27(19) °C and outdoor temperature Tj				
Tj = 35 °C	Pdc	10.00	10.030	kW	Tj = 35 °C	EERd	3.80	3.83	—
Tj = 30 °C	Pdc	7.40	7.510	kW	Tj = 30 °C	EERd	5.50	5.55	—
Tj = 25 °C	Pdc	4.70	4.780	kW	Tj = 25 °C	EERd	7.65	7.70	—
Tj = 20 °C	Pdc	2.60	2.660	kW	Tj = 20 °C	EERd	13.40	13.45	—

Declared capacity (*) for heating/Average season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Average season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = -7 °C	Pdh	7.04	7.060	kW	Tj = -7 °C	COPd	2.96	3.00	—
Tj = 2 °C	Pdh	4.32	4.430	kW	Tj = 2 °C	COPd	4.30	4.35	—
Tj = 7 °C	Pdh	2.80	2.875	kW	Tj = 7 °C	COPd	5.68	5.71	—
Tj = 12 °C	Pdh	2.40	2.610	kW	Tj = 12 °C	COPd	6.70	6.83	—
Tj = bivalent temperature	Pdh	7.04	7.060	kW	Tj = bivalent temperature	COPd	2.96	3.00	—
Tj = operating limit	Pdh	7.40	7.420	kW	Tj = operating limit	COPd	2.50	2.59	—

Declared capacity (*) for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = 2 °C	Pdh	8.00	8.020	kW	Tj = 2 °C	COPd	3.30	3.32	—
Tj = 7 °C	Pdh	5.12	5.200	kW	Tj = 7 °C	COPd	4.74	4.83	—
Tj = 12 °C	Pdh	2.32	2.360	kW	Tj = 12 °C	COPd	6.43	6.44	—
Tj = bivalent temperature	Pdh	8.00	8.020	kW	Tj = bivalent temperature	COPd	3.30	3.32	—
Tj = operating limit	Pdh	8.00	8.020	kW	Tj = operating limit	COPd	3.30	3.32	—

Declared capacity (*) for heating/Colder season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Colder season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = -7 °C	Pdh	NA	NA	kW	Tj = -7 °C	COPd	NA	NA	—
Tj = 2 °C	Pdh	NA	NA	kW	Tj = 2 °C	COPd	NA	NA	—
Tj = 7 °C	Pdh	NA	NA	kW	Tj = 7 °C	COPd	NA	NA	—
Tj = 12 °C	Pdh	NA	NA	kW	Tj = 12 °C	COPd	NA	NA	—
Tj = bivalent temperature	Pdh	NA	NA	kW	Tj = bivalent temperature	COPd	NA	NA	—
Tj = operating limit	Pdh	NA	NA	kW	Tj = operating limit	COPd	NA	NA	—
Tj = -15 °C	Pdh	NA	NA	kW	Tj = -15 °C	COPd	NA	NA	—

Bivalent temperature					Operating limit temperature				
heating/Average	Tbiv	-7	NA	°C	heating/Average	Tol	-10	NA	°C
heating/Warmer	Tbiv	2	NA	°C	heating/Warmer	Tol	2	NA	°C

heating/Colder	Tbiv	NA	NA	°C	heating/Colder	Tol	NA	NA	°C
Power consumption of cycling					Efficiency of cycling				
cooling	P _{cycc}	NA	NA	kW	cooling	EER _{cycc}	NA	NA	—
heating	P _{cyh}	NA	NA	kW	heating	COP _{cyh}	NA	NA	—
Degradation co-efficient cooling (**)	Cdc	0.25	NA	—	Degradation co-efficient heating (**)	Cdh	0.25	NA	—
Electric power input in power modes other than 'active mode'					Seasonal electricity consumption				
off mode	P _{OFF}	0.010	0.010	kW	cooling	Q _{CE}	491	487	kWh/a
standby mode	P _{SB}	0.010	0.010	kW	heating/Average	Q _{HE}	2545	2517	kWh/a
thermostat-off mode	P _{TO}	0.002	0.002	kW	heating/Warmer	Q _{HE}	2093	2074	kWh/a
crankcase heater mode	P _{CK}	0.000	0.000	kW	heating/Colder	Q _{HE}	NA	NA	kWh/a
Capacity control (indicate one of three options)					Other items				
fixed	N				Sound power level (indoor)	LWA	62	61.2	dB(A)
					Sound power level (outdoor)	LWA	68	67.2	dB(A)
staged	N				Global warming potential	GWP	675	1.836	kgCO ₂ eq.
variable	Y				Rated air flow (indoor/outdoor)	—	—	—	m ³ /h
TEST CONCLUSION: 测试结论									
Are the SEER and SCOP TEST results Compliant or Non-Compliant? SEER/SCOP测试是否符合要求?							Compliant		

徐金宇



Tested by (name + signature)

测试员 (姓名, 签名)

Approved by (name + signature)

批准人 (姓名, 签名)