

EU SEER/SCOP Test 欧盟SEER/SCOP测试

Version 1.0

Test Standard 测试标准: (EU) No 626/2011 (EU) No 206/2012 EN14825 EN 14511 ENV 12102 Other _____

GPA requirement: 产品审批要求:

GPA requirement for rated SEER
GPA 的额定制冷季节能效比要求 (%) >=100%

GPA requirement for rated SCOP
GPA 的额定制热季节性能系数要求 (%) >=100%

GPA requirement for Sound Power
GPA 的声功率要求 <=Rated

Inverter Single Split type 变频一拖一 分体机 On/off Single Split type 定速一拖一 分体机 Inverter Multisplit type 变频一拖多 分体机 On/off Multisplit type 定速一拖多 分体机

ERP Hisense Mode: 欧洲海信型号: AUV125UR4RC8+AUV125U6RN8 Manufacturer Model: 工厂型号: AUV-42UR4RC8+AUV-42U6RN8

Test Result:

Function (indicate to which function information applies) If function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'.

Cooling	Y	Average (mandatory)	Y
Heating	Y	Warmer (if designated)	Y
		Colder (if designated)	N

Item	Symbol	Rated value	Tested Value	Unit	Item	symbol	Rated value	Tested Value	unit
------	--------	-------------	--------------	------	------	--------	-------------	--------------	------

Design load					Seasonal efficiency				
cooling	Pdesignc	12.10	12.400	kW	cooling	SEER	6.00	6.04	—
heating/Average	Pdesignh	9.00	9.010	kW	heating/Average	SCOP(A)	4.30	4.37	—
heating/Warmer	Pdesignh	9.00	9.010	kW	heating/Warmer	SCOP(W)	5.31	5.34	—
heating/Colder	Pdesignh	NA	NA	kW	heating/Colder	SCOP(C)	NA	NA	—

Declared capacity (*) for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj					Declared energy efficiency ratio (*), at indoor temperature 27(19) °C and outdoor temperature Tj				
Tj = 35 °C	Pdc	12.10	12.400	kW	Tj = 35 °C	EERd	3.07	3.13	—
Tj = 30 °C	Pdc	8.95	9.010	kW	Tj = 30 °C	EERd	4.55	4.58	—
Tj = 25 °C	Pdc	5.69	5.780	kW	Tj = 25 °C	EERd	6.80	6.83	—
Tj = 20 °C	Pdc	3.46	3.470	kW	Tj = 20 °C	EERd	10.15	10.25	—

Declared capacity (*) for heating/Average season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Average season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = -7 °C	Pdh	7.92	7.950	kW	Tj = -7 °C	COPd	2.92	2.94	—
Tj = 2 °C	Pdh	4.86	4.900	kW	Tj = 2 °C	COPd	4.20	4.28	—
Tj = 7 °C	Pdh	3.15	3.220	kW	Tj = 7 °C	COPd	5.50	5.60	—
Tj = 12 °C	Pdh	2.96	2.980	kW	Tj = 12 °C	COPd	6.50	6.63	—
Tj = bivalent temperature	Pdh	7.92	7.950	kW	Tj = bivalent temperature	COPd	2.92	2.94	—
Tj = operating limit	Pdh	9.00	9.010	kW	Tj = operating limit	COPd	2.34	2.39	—

Declared capacity (*) for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = 2 °C	Pdh	9.00	9.010	kW	Tj = 2 °C	COPd	2.65	2.72	—
Tj = 7 °C	Pdh	5.76	5.780	kW	Tj = 7 °C	COPd	4.80	4.83	—
Tj = 12 °C	Pdh	2.61	2.640	kW	Tj = 12 °C	COPd	6.50	6.50	—
Tj = bivalent temperature	Pdh	9.00	9.010	kW	Tj = bivalent temperature	COPd	2.65	2.72	—
Tj = operating limit	Pdh	9.00	9.010	kW	Tj = operating limit	COPd	2.65	2.72	—

Declared capacity (*) for heating/Colder season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Colder season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = -7 °C	Pdh	NA	NA	kW	Tj = -7 °C	COPd	NA	NA	—
Tj = 2 °C	Pdh	NA	NA	kW	Tj = 2 °C	COPd	NA	NA	—
Tj = 7 °C	Pdh	NA	NA	kW	Tj = 7 °C	COPd	NA	NA	—
Tj = 12 °C	Pdh	NA	NA	kW	Tj = 12 °C	COPd	NA	NA	—
Tj = bivalent temperature	Pdh	NA	NA	kW	Tj = bivalent temperature	COPd	NA	NA	—
Tj = operating limit	Pdh	NA	NA	kW	Tj = operating limit	COPd	NA	NA	—
Tj = -15 °C	Pdh	NA	NA	kW	Tj = -15 °C	COPd	NA	NA	—

Bivalent temperature					Operating limit temperature				
heating/Average	Tbiv	-7	NA	°C	heating/Average	Tol	-10	NA	°C
heating/Warmer	Tbiv	2	NA	°C	heating/Warmer	Tol	2	NA	°C

heating/Colder	Tbiv	NA	NA	°C	heating/Colder	Tol	NA	NA	°C
Power consumption of cycling					Efficiency of cycling				
cooling	P _{cycc}	NA	NA	kW	cooling	EER _{cycc}	NA	NA	—
heating	P _{cyh}	NA	NA	kW	heating	COP _{cyh}	NA	NA	—
Degradation co-efficient cooling (**)	Cdc	0.25	NA	—	Degradation co-efficient heating (**)	Cdh	0.25	NA	—
Electric power input in power modes other than 'active mode'					Seasonal electricity consumption				
off mode	P _{OFF}	0.011	0.011	kW	cooling	Q _{CE}	705	701	kWh/a
standby mode	P _{SB}	0.011	0.011	kW	heating/Average	Q _{HE}	2930	2882	kWh/a
thermostat-off mode	P _{TO}	0.002	0.002	kW	heating/Warmer	Q _{HE}	2373	2360	kWh/a
crankcase heater mode	P _{CK}	0.000	0.000	kW	heating/Colder	Q _{HE}	NA	NA	kWh/a
Capacity control (indicate one of three options)					Other items				
fixed		N			Sound power level (indoor)	LWA	71	70.3	dB(A)
					Sound power level (outdoor)	LWA	69	68.4	dB(A)
staged		N			Global warming potential	GWP	675	2.025	kgCO ₂ eq.
variable		Y			Rated air flow (indoor/outdoor)	—	—	—	m ³ /h
TEST CONCLUSION: 测试结论									
Are the SEER and SCOP TEST results Compliant or Non-Compliant? SEER/SCOP测试是否符合要求?							Compliant		

徐金宇



Tested by (name + signature)

测试员 (姓名, 签名)

Approved by (name + signature)

批准人 (姓名, 签名)