

EU SEER/SCOP Test 欧盟SEER/SCOP测试

Version 1.0

Test Standard 测试标准:	<input checked="" type="checkbox"/> (EU) No 626/2011 <input checked="" type="checkbox"/> (EU) No 206/2012 <input checked="" type="checkbox"/> EN14825 <input checked="" type="checkbox"/> EN 14511 <input checked="" type="checkbox"/> EN12102 <input type="checkbox"/> Other: _____
---------------------	--

GPA requirement: 产品审批要求:	
GPA requirement for rated SEER GPA 的额定制冷季节能效比要求 (%) <div style="border: 1px solid black; padding: 2px; display: inline-block; margin-left: 10px;">>=100%</div>	GPA requirement for rated SCOP GPA 的额定制热季节性能系数要求 (%) <div style="border: 1px solid black; padding: 2px; display: inline-block; margin-left: 10px;">>=100%</div>
GPA requirement for Sound Power GPA 的声功率要求 <div style="border: 1px solid black; padding: 2px; display: inline-block; margin-left: 10px;"><=Rated</div>	
<input checked="" type="checkbox"/> Inverter Single Split type 变频一拖一 分体机 <input checked="" type="checkbox"/> On/off Single Split type 定速一拖一 分体机 <input type="checkbox"/> Inverter Multisplit type 变频一拖多 分体机 <input type="checkbox"/> On/off Multisplit type 定速一拖多 分体机	

ERP Hisense Mode: 欧洲海信型号:	ADT52UX4RCL8&AUW52U4RS7	Manufacturer Model: 工厂型号:	ADT-18UX4RCL8&AUW-18U4RS7
------------------------------	-------------------------	------------------------------	---------------------------

Test Result:	
Function (indicate to which function information applies)	If function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'.

Cooling		Y				Y			
Heating		Y				Y			
						N			

Item	Symbol	Rated value	Tested Value	Unit	Item	symbol	Rated value	Tested Value	unit
------	--------	-------------	--------------	------	------	--------	-------------	--------------	------

Design load					Seasonal efficiency				
cooling	Pdesignc	5.00	5.000	kW	cooling	SEER	7.00	7.22	—
heating/Average	Pdesignh	4.00	4.000	kW	heating/Average	SCOP(A)	4.30	4.39	—
heating/Warmer	Pdesignh	4.00	4.000	kW	heating/Warmer	SCOP(W)	5.40	5.49	—
heating/Colder	Pdesignh	NA	NA	kW	heating/Colder	SCOP(C)	NA	NA	—

Declared capacity (*) for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj					Declared energy efficiency ratio (*), at indoor temperature 27(19) °C and outdoor temperature Tj				
Tj = 35 °C	Pdc	5.00	5.068	kW	Tj = 35 °C	EERd	3.50	3.61	—
Tj = 30 °C	Pdc	3.70	3.780	kW	Tj = 30 °C	EERd	5.30	5.36	—
Tj = 25 °C	Pdc	2.35	2.430	kW	Tj = 25 °C	EERd	8.40	8.58	—
Tj = 20 °C	Pdc	1.25	1.352	kW	Tj = 20 °C	EERd	13.60	14.32	—

Declared capacity (*) for heating/Average season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Average season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = -7 °C	Pdh	3.52	3.624	kW	Tj = -7 °C	COPd	2.86	2.86	—
Tj = 2 °C	Pdh	2.16	2.165	kW	Tj = 2 °C	COPd	4.30	4.30	—
Tj = 7 °C	Pdh	1.40	1.434	kW	Tj = 7 °C	COPd	5.50	5.90	—
Tj = 12 °C	Pdh	1.04	1.113	kW	Tj = 12 °C	COPd	6.00	6.38	—
Tj = bivalent temperature	Pdh	3.52	3.624	kW	Tj = bivalent temperature	COPd	2.86	2.86	—
Tj = operating limit	Pdh	3.30	3.348	kW	Tj = operating limit	COPd	2.50	2.50	—

Declared capacity (*) for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = 2 °C	Pdh	4.00	4.100	kW	Tj = 2 °C	COPd	3.30	3.32	—
Tj = 7 °C	Pdh	2.56	2.630	kW	Tj = 7 °C	COPd	4.92	4.92	—
Tj = 12 °C	Pdh	1.16	1.190	kW	Tj = 12 °C	COPd	6.40	6.44	—
Tj = bivalent temperature	Pdh	4.00	4.100	kW	Tj = bivalent temperature	COPd	3.30	3.32	—
Tj = operating limit	Pdh	4.00	4.100	kW	Tj = operating limit	COPd	3.30	3.32	—

Declared capacity (*) for heating/Colder season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Colder season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = -7 °C	Pdh	NA	NA	kW	Tj = -7 °C	COPd	NA	NA	—
Tj = 2 °C	Pdh	NA	NA	kW	Tj = 2 °C	COPd	NA	NA	—
Tj = 7 °C	Pdh	NA	NA	kW	Tj = 7 °C	COPd	NA	NA	—
Tj = 12 °C	Pdh	NA	NA	kW	Tj = 12 °C	COPd	NA	NA	—
Tj = bivalent temperature	Pdh	NA	NA	kW	Tj = bivalent temperature	COPd	NA	NA	—
Tj = operating limit	Pdh	NA	NA	kW	Tj = operating limit	COPd	NA	NA	—
Tj = -15 °C	Pdh	NA	NA	kW	Tj = -15 °C	COPd	NA	NA	—

Bivalent temperature					Operating limit temperature				
heating/Average	Tbiv	-7	NA	°C	heating/Average	Tol	-10	NA	°C
heating/Warmer	Tbiv	2	NA	°C	heating/Warmer	Tol	2	NA	°C

heating/Colder	Tbiv	NA	NA	°C	heating/Colder	Tol	NA	NA	°C
Power consumption of cycling					Efficiency of cycling				
cooling	Pcyc	NA	NA	kW	cooling	EERcyc	NA	NA	—
heating	Pych	NA	NA	kW	heating	COPcyc	NA	NA	—
Degradation co-efficient cooling (**)	Cdc	0.25	NA	—	Degradation co-efficient heating (**)	Cdh	0.25	NA	—
Electric power input in power modes other than 'active mode'					Seasonal electricity consumption				
off mode	P _{OFF}	0.007	0.007	kW	cooling	Q _{CE}	250	250	kWh/a
standby mode	P _{SB}	0.007	0.007	kW	heating/Average	Q _{HE}	1302	1302	kWh/a
thermostat-off mode	P _{TO}	0.012	0.012	kW	heating/Warmer	Q _{HE}	1037	1037	kWh/a
crankcase heater mode	P _{CK}	0.000	0.000	kW	heating/Colder	Q _{HE}	NA	NA	kWh/a
Capacity control (indicate one of three options)					Other items				
fixed	N				Sound power level (indoor)	LWA	57	60.9	dB(A)
					Sound power level (outdoor)	LWA	63	62.7	dB(A)
staged	N				Global warming potential	GWP	675	0.709	kgCO ₂ eq.
variable	Y				Rated air flow (indoor/outdoor)	—	—	—	m ³ /h
TEST CONCLUSION: 测试结论									
Are the SEER and SCOP TEST results Compliant or Non-Compliant? SEER/SCOP测试是否符合要求?							Compliant		

徐金宇



Tested by (name + signature)

测试员 (姓名, 签名)

Approved by (name + signature)

批准人 (姓名, 签名)