

heating/Colder	Tbiv	NA	NA	°C	heating/Colder	Tol	NA	NA	°C
Power consumption of cycling					Efficiency of cycling				
cooling	Pcyc	NA	NA	kW	cooling	EERcyc	NA	NA	—
heating	Pych	NA	NA	kW	heating	COPcyc	NA	NA	—
Degradation co-efficient cooling (**)	Cdc	0.25	NA	—	Degradation co-efficient heating (**)	Cdh	0.25	NA	—
Electric power input in power modes other than 'active mode'					Seasonal electricity consumption				
off mode	P _{OFF}	0.009	0.009	kW	cooling	Q _{CE}	340	343	kWh/a
standby mode	P _{SB}	0.009	0.009	kW	heating/Average	Q _{HE}	1674	1674	kWh/a
thermostat-off mode	P _{TO}	0.001	0.001	kW	heating/Warmer	Q _{HE}	1426	1413	kWh/a
crankcase heater mode	P _{CK}	0.000	0.000	kW	heating/Colder	Q _{HE}	NA	NA	kWh/a
Capacity control (indicate one of three options)					Other items				
fixed	N				Sound power level (indoor)	LWA	54	53.5	dB(A)
					Sound power level (outdoor)	LWA	68	67.4	dB(A)
staged	N				Global warming potential	GWP	675	0.709	kgCO ₂ eq.
variable	Y				Rated air flow (indoor/outdoor)	—	—	—	m ³ /h
TEST CONCLUSION: 测试结论									
Are the SEER and SCOP TEST results Compliant or Non-Compliant? SEER/SCOP测试是否符合要求?							Compliant		

徐金宇



Tested by (name + signature)

测试员 (姓名, 签名)

Approved by (name + signature)

批准人 (姓名, 签名)