

EU SEER/SCOP Test 欧盟SEER/SCOP测试

Version 1.0

Test Standard 测试标准: (EU) No 626/2011 (EU) No 206/2012 EN14825 EN 14511 ENV 12102 Other_____

GPA requirement: 产品审批要求:

GPA requirement for rated SEER
GPA 的额定制冷季节能效比要求 (%) >=100%

GPA requirement for rated SCOP
GPA 的额定制热季节性能系数要求 (%) >=100%

GPA requirement for Sound Power
GPA 的声功率要求 <=Rated

Inverter Single Split type 变频一拖一 分体机 On/off Single Split type 定速一拖一 分体机 Inverter Multisplit type 变频一拖多 分体机 On/off Multisplit type 定速一拖多 分体机

ERP Hisense Mode: 欧洲海信型号: AVT71UR4RB8 & AUW71U4RJ7 Manufacturer Model: 工厂型号: AVT-24UR4RB8 & AUW-24U4RJ7

Test Result:

Function (indicate to which function information applies) If function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'.

Cooling		Y				Average (mandatory)		Y
Heating		Y				Warmer (if designated)		Y
						Colder (if designated)		N

Item	Symbol	Rated value	Tested Value	Unit	Item	symbol	Rated value	Tested Value	unit
------	--------	-------------	--------------	------	------	--------	-------------	--------------	------

Design load					Seasonal efficiency				
cooling	Pdesignc	7.00	7.000	kW	cooling	SEER	6.30	6.35	—
heating/Average	Pdesignh	5.50	5.500	kW	heating/Average	SCOP(A)	4.20	4.25	—
heating/Warmer	Pdesignh	5.50	5.500	kW	heating/Warmer	SCOP(W)	5.35	5.38	—
heating/Colder	Pdesignh	NA	NA	kW	heating/Colder	SCOP(C)	NA	NA	—

Declared capacity (*) for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj					Declared energy efficiency ratio (*), at indoor temperature 27(19) °C and outdoor temperature Tj				
Tj = 35 °C	Pdc	7.00	7.050	kW	Tj = 35 °C	EERd	3.24	3.25	—
Tj = 30 °C	Pdc	5.18	5.250	kW	Tj = 30 °C	EERd	4.65	4.73	—
Tj = 25 °C	Pdc	3.29	3.330	kW	Tj = 25 °C	EERd	7.10	7.17	—
Tj = 20 °C	Pdc	1.65	1.750	kW	Tj = 20 °C	EERd	12.80	12.86	—

Declared capacity (*) for heating/Average season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Average season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = - 7 °C	Pdh	4.84	4.940	kW	Tj = - 7 °C	COPd	2.95	3.01	—
Tj = 2 °C	Pdh	2.97	2.980	kW	Tj = 2 °C	COPd	3.95	4.00	—
Tj = 7 °C	Pdh	1.93	1.960	kW	Tj = 7 °C	COPd	5.60	5.65	—
Tj = 12 °C	Pdh	1.30	1.360	kW	Tj = 12 °C	COPd	6.20	6.26	—
Tj = bivalent temperature	Pdh	4.84	4.940	kW	Tj = bivalent temperature	COPd	2.95	3.01	—
Tj = operating limit	Pdh	5.30	5.370	kW	Tj = operating limit	COPd	2.50	2.58	—

Declared capacity (*) for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = 2 °C	Pdh	5.50	5.580	kW	Tj = 2 °C	COPd	3.10	3.13	—
Tj = 7 °C	Pdh	3.52	3.520	kW	Tj = 7 °C	COPd	4.95	4.98	—
Tj = 12 °C	Pdh	1.60	1.670	kW	Tj = 12 °C	COPd	6.25	6.29	—
Tj = bivalent temperature	Pdh	5.50	5.580	kW	Tj = bivalent temperature	COPd	3.10	3.13	—
Tj = operating limit	Pdh	5.50	5.580	kW	Tj = operating limit	COPd	3.10	3.13	—

Declared capacity (*) for heating/Colder season, at indoor temperature 20 °C and outdoor temperature Tj					Declared coefficient of performance (*)/Colder season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = - 7 °C	Pdh	NA	NA	kW	Tj = - 7 °C	COPd	NA	NA	—
Tj = 2 °C	Pdh	NA	NA	kW	Tj = 2 °C	COPd	NA	NA	—
Tj = 7 °C	Pdh	NA	NA	kW	Tj = 7 °C	COPd	NA	NA	—
Tj = 12 °C	Pdh	NA	NA	kW	Tj = 12 °C	COPd	NA	NA	—
Tj = bivalent temperature	Pdh	NA	NA	kW	Tj = bivalent temperature	COPd	NA	NA	—
Tj = operating limit	Pdh	NA	NA	kW	Tj = operating limit	COPd	NA	NA	—
Tj = - 15 °C	Pdh	NA	NA	kW	Tj = - 15 °C	COPd	NA	NA	—

Bivalent temperature					Operating limit temperature				
heating/Average	Tbiv	-7	NA	°C	heating/Average	Tol	-10	NA	°C
heating/Warmer	Tbiv	2	NA	°C	heating/Warmer	Tol	2	NA	°C

heating/Colder	T _{biv}	NA	NA	°C	heating/Colder	T _{ol}	NA	NA	°C
Power consumption of cycling					Efficiency of cycling				
cooling	P _{cycc}	NA	NA	kW	cooling	EER _{cycc}	NA	NA	—
heating	P _{cyh}	NA	NA	kW	heating	COP _{cyh}	NA	NA	—
Degradation co-efficient cooling (**)	C _{dc}	0.25	NA	—	Degradation co-efficient heating (**)	C _{dh}	0.25	NA	—
Electric power input in power modes other than 'active mode'					Seasonal electricity consumption				
off mode	P _{OFF}	0.008	0.008	kW	cooling	Q _{CE}	389	389	kWh/a
standby mode	P _{SB}	0.008	0.008	kW	heating/Average	Q _{HE}	1833	1812	kWh/a
thermostat-off mode	P _{TO}	0.001	0.001	kW	heating/Warmer	Q _{HE}	1439	1431	kWh/a
crankcase heater mode	P _{CK}	0.000	0.000	kW	heating/Colder	Q _{HE}	NA	NA	kWh/a
Capacity control (indicate one of three options)					Other items				
fixed	N				Sound power level (indoor)	LWA	62	60.9	dB(A)
					Sound power level (outdoor)	LWA	68	66.9	dB(A)
staged	N				Global warming potential	GWP	675	0.709	kgCO ₂ eq.
variable	Y				Rated air flow (indoor/outdoor)	—	—	—	m ³ /h
TEST CONCLUSION: 测试结论									
Are the SEER and SCOP TEST results Compliant or Non-Compliant? SEER/SCOP测试是否符合要求?							Compliant		

徐金宇



Tested by (name + signature)

测试员 (姓名, 签名)

Approved by (name + signature)

批准人 (姓名, 签名)